

# Empty cabinet


Type GSAB 2S1000

inspected according VDE 0660 part 500 / IEC 439-1  
 inspected by TÜV according DIN EN 60439-5

protection class of cabinet : IP44  
 class of protection II (with electrical insulation)  
 made of : fibreglass-reinforced polyester  
 (SMC process), IEC-695-2-1, halogen-free  
 colour : grey, similar to RAL 7035  
 lock: single swing handle  
 (with profile cylinder lock inside)  
 dual swing handle possible for surcharge

optional:

- protection class IP54
- RAL-painting



			Datum	10.12.2013	Project:Empty cabinet <b>Best.-Nr:2S1000</b>	Ang.-Nr.:		=
			Bearb.	M.Biermann		Auf.-Nr.:		+
			Gepr.					
Zust.	Anderung	Datum	Name	Norm	Urspr.	Ers.f.	Ers.d.	
								Lindenstraße 23 Tel: 49/03636/7614-76 Bl. 1 v. 99718 Greußen Fax: 49/03636/7614-30 1 Bl.



**GSAB**  
 Elektrotechnik GmbH