

Distributor cabinet

according DIN 43870 bdeu guideline 2008
 inspected according VDE 0660 part 500 / IEC 439-1
 inspected by TÜV according DIN EN 60439-5


protection class of cabinet : IP44
 class of protection II (with electrical insulation)
 made of : fibreglass-reinforced polyester
 (SMC process), IEC-695-2-1, halogen-free
 colour : grey, similar to RAL 7035
 lock: single swing handle
 (with profile cylinder lock inside)

contains the following items:

- 4-pole busbar system

optional:

- filling material for base SFM2
- cable slot in the base
- RAL-painting on the outside



Type of cabinet:
 GSAB 2S1000
 H: 1020+950
 W: 1135
 D: 320

| | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|--------|------------|---|--------|--------|--------|------|------|-------|----------|-------|------------|-----|----|---|---|----------------------------------|--|------------|----|-----|
| | | | Datum | 16.12.2013 | Projek: Distributor cabinet Bst.Nr.: 2S1000K | Ers.d. | Ers.f. | Urspr. | Norm | Name | Datum | Anderung | Zust. | Bl. 1 v. 1 | Bl. | v. | = | + | Lindenstraße 23 99718 Greußen | Tel: 49/03636/7614-76 Fax: 49/03636/7614-30 | Bl. 1 v. 1 | v. | Bl. |
| | | | Bearb. | M.Biermann | | | | | | | | | | | | | | | | | | | |
| | | | Gepr. | | | | | | | | | | | | | | | | | | | | |



GSAB
 Elektrotechnik GmbH

Lindenstraße 23 Tel: 49/03636/7614-76
 99718 Greußen Fax: 49/03636/7614-30