

**system hook-panel CEE32+2xplugs (Schuko)
according to DIN EN 60439-1
according to VDE 0660 part 500
IEC 60439-1:1999 +A1:2004**

system hook-panel for distribution and metering cabinets


-fixation und connection on busbar system 185mm
(as vertical disconnection fuse NH2)

contains the following items:

- D02-fusebase 3-pol.
- FI-switch 40/4/0,03
- C32/3+CEE32
- 2xLS-switch B16+2xplugs(Schuko)

security informations!

The assembling/mounting of these system hook-panel has to be made only by qualified personnel! If other people will have access to these cabinets with system hook-panels, the installer/or the operator must protect these parts against accidental contact



in mm:

H : 710

W: 100

D : 165

			Datum	12.02.08	project: hook-panel Schuko	Ang.-Nr.:	
			Bearb.	J.Stolp	order-no.:99.00.026	Auf.-Nr.:	
Zust.	Anderung	Datum	Name	Norm	Urspr.	Ers.f.	Ers.d.



GSAB
Elektrotechnik GmbH

		=	
		+	
Lindenstraße 23 99718 Greußen	Tel: 49/03636/7614-76 Fax: 49/03636/7614-30	Bl. 1	v. 1 Bl.